

TEST REPORT

Lucideon Reference: 164962 (QT39584/2/JPS)/Ref. 8/Supp1

Project Title: Testing of Balustrade System TL-6030 in Accordance with BS 6180:2011 Barriers In and About Buildings

Client: OnLevel Gmbh
Groendahlscher Weg 87
46446 Emmerich
Germany

For the Attention of: Mr Frank Verhey

Author(s): Miss Lisa Cobden

Report Date: 27 March, 2017

Purchase Order No.: 71160562 FV

Work Location: Lucideon UK

This report supersedes the report issued on 16.03.17.



Miss Joanne Booth
Consultancy Team
Reviewer



Miss Lisa Cobden
Consultancy Team
Project Manager



CONTENTS

	Page
1 INTRODUCTION	3
2 TEST SAMPLES	3
3 TEST PROGRAMME	3
4 TEST METHOD	3
5 RESULTS	4
TABLES	5-6
PLATE	7
CHART	8
APPENDIX - Figures	

1 INTRODUCTION

Lucideon were commissioned by the client, OnLevel Gmbh, to carry out load testing in accordance with BS 6180:2011 Barriers in and about buildings, to allow their balustrade system to be classified for use in accordance with BS 6180:2011 Barriers in and about buildings – Code of Practice.

The testing was carried out at OnLevel's facilities at Innovatielaan 25 8447 SN Heerenveen The Netherlands.

This report summarises the test results obtained during the test programme and does not provide interpretation of those results.

2 TEST SAMPLES

The aluminium channel tested was designated as System TL-6030. The system is shown in Figure 1.

The channel was installed by OnLevel personnel.

3 TEST PROGRAMME

A horizontal line load was carried out on the aluminium channel with the following glass types installed:

- Laminated Tempered Glass with PVB Foil 15/15/4 31.52 mm – size (w x h): 1000 mm x 1171 mm.
- Laminated Tempered Glass with PVB Foil 12/12/4 25.52 mm – size (w x h): 1000 mm x 1221 mm.
- Laminated Tempered Glass with PVB Foil 10/10/4 21.52 mm – size (w x h): 1000 mm x 1071 mm.

4 TEST METHOD

The channel was bolted to the top of a concrete block, nominally 0.5 m x 0.5 m x 3.5 m which was fixed to the floor of the test facility. The channel was bolted to the block at 100 mm centres by the client using the appropriate fixings (see Figure 1 and 2).

The appropriate thickness glass panel was fitted into the channel using the 'Flex Fit' fixing clips at nominally 312.5 mm centres such that the plastic clip was to the outside face of the glass (see Figures 3 and 4).

A horizontal imposed line load was applied to the glass panel at a height of between 1100 mm and 1250 mm above the datum level of the floor and the deflection measured at the top central point of the panel. The exact height at which the load was applied and the deflection measured for each individual panel can be found in Table 1. The load was applied via a hydraulic ram and the deflection measured using a digital electronic displacement transducer, (see Plate 1).



5 RESULTS

The test was carried out in accordance with the guidance given in BS 6180 Barriers in and about buildings – Code of Practice. The standard states that the maximum allowable deflection for a free standing glass protective barrier panel is 25 mm.

Table 2 of BS 6180 Barriers in and about buildings – Code of Practice categorises parapets, barriers and balustrades for areas of use depending on the loads they have achieved under testing.

The loads achieved by the OnLevel glazing system tested under horizontal imposed line load to the maximum deflection of 25 mm are given in Table 1.

All figures quoted in Table 1 contain no safety factors and are direct loads as achieved by the system under test conditions.

Table 2 summarises the suitability of the tested systems in accordance with Table 2 of BS 6180:2011.

NOTE: The results given in this report apply only to the samples that have been tested.

END OF REPORT



Table 1 - Summary of Performance of OnLevel Balustrade System
Tested under Horizontal Imposed Line Load

Base Rail	Glass	Height of Applied Load mm	Imposed Line Load at 25 mm Deflection (kN/m)	Working Line Load for System (kN/m)	Deflection at Working Line Load for System (mm)
System TL-6030	10/10/4	1100	1.50	1.50	25.00
	12/12/4	1250	1.54	1.50	22.79
	15/15/4	1200	3.03	3.00	23.73

Table 2 - Summary of Suitability of OnLevel Balustrade Systems in Accordance with Table 2 of BS 6180:2011

Type of Occupancy for Part of the Building	Examples of Specific Use	Horizontal Uniformly Distributed Line Load (kN/m)	TL-6030		
			15/15/4 1200 mm	12/12/4 1250 mm	10/10/4 1100 mm
Domestic and residential activities	(i) all areas within or serving exclusively one single family dwelling including stairs, landings, etc. but excluding external balconies and edges of roofs	0.36	✓	✓	✓
	(ii) other residential, i. e. houses of multiple occupancy and balconies, including Juliette balconies and edges of roofs in single family dwellings	0.74	✓	✓	✓
Offices and work areas not included elsewhere, including storage areas	(iii) light access stairs and gangways not more than 600 mm wide	0.22	✓	✓	✓
	(iv) light pedestrian traffic routes in industrial and storage buildings except designated escape routes	0.36	✓	✓	✓
	(v) areas not susceptible to overcrowding in office and institutional buildings, also industrial and storage buildings except as given above	0.74	✓	✓	✓
Areas where people might congregate	(vi) areas having fixed seating within 530 mm of the barrier, balustrade or parapet	1.50	✓	✓	✓
Areas with tables or fixed seating	(vii) restaurants and bars	1.50	✓	✓	✓
Areas without obstacles for moving people and not susceptible to overcrowding	(viii) stairs, landings corridors ramps	0.74	✓	✓	✓
	(ix) external balconies including Juliette balconies and edges of roofs; footways and pavements within building cartilage adjacent to basement/sunken areas	0.74	✓	✓	✓
Areas susceptible to overcrowding	(x) footways or pavements less than 3 m wide adjacent to sunken areas	1.50	✓	✓	✓
	(xi) theatres, cinemas, discotheques, bars, auditoria, shopping malls, assembly areas, studios; footways or pavements greater than 3 m wide adjacent to sunken areas	3.00	✓	X	X
	(xii) grandstands and stadia	(Note 1)	-	-	-
Retail areas	(xiii) all retail areas including public areas of banks/building societies or betting shops	1.50	✓	✓	✓
Vehicular	(xiv) pedestrian areas in car parks, including stairs, landings, ramps, edges of internal floors, footways, edges of roofs	1.50(Note 2)	✓	✓	✓
	(xv) horizontal loads imposed by vehicles	(Note 2)	-	-	-

Note 1 – See requirements of the appropriate certifying authority

Note 2 – Clause 8.1.1 of BS 6180:2011 states that “glass should not be used for vehicle protection barriers”




Plate 1 - Generic Test Arrangement




Chart 1 - Load Versus Defelction Curves for OnLevel Balustrades System TL-6030

Test Report: 164962/Ref. 8/Supp1





Key — 10 10 4 — 12 12 4 — 15 15 4

APPENDIX - Figures



1. Glass profile TL-6030, top mount
Aluminium 6063-T6
2. Glass 15/15/4 (31,52mm), 12/12/4 (25,52),
10/10/4 (21,52)
3. Glass carrier set
Model 0502/0505
ABS-GF30
4. Wedge
ABS-GF30
5. Glasrubber
TPE, hardness 75°, shore A
6. Anchor Fischer FH II 12/15Sk
Model 91.3511.215.81/ 91.3511.215.30)
(or comparable anchor)

Designed by FV	Created 09-Dec-16	Modified	Comment
		Description Detail:Figure 1	
		Article number TL-6030 (top mount)	Size A4







Designed by FV	Created 09-Dec-16	Modified	Comment
		Description Detail: Figure 2 (Line Load / Glass Heights)	
		Article number TL-6030 (top mount)	Size A4

Figure 3



Material: Aluminum 6063-T6




Designed by FV	Created 09-Dec-16	Modified	Comment	
		Description Profile TL-6030 L = 2500mm		
		Article number TL-6030 (top mount)	Size A4	Scale -

Figure 4



ITEM	PCS (L=2500mm)	PCS (L = 5000mm)	Description
1	8	16	Flex-Fit 3.0kN
2	8	16	Glass Wedge 3.0kN
3	1 (L=2500mm)	1 (L=5000mm)	Rubber User Side
4	1 (L=2500mm)	1 (L=5000mm)	Rubber Falling Side

Distance Glass Carrier
/ Glass Wedges :



Designed by FV	Created 09-Dec-16	Modified	Comment
		Description Flex-Fits sets (quantity and distance)	
		Article number TL-6030 (top mount)	Size A4